

9. 2) STATE SRF APPLICATIONS

e) HENRIEVILLE EMERGENCY

HENRIEVILLE WATER EMERGENCY

The Division of Drinking Water staff received a report on Wednesday, February 20, 2008 that a mudslide washed out approximately 800 feet of water transmission line between Henrieville's storage tank and the community water distribution system resulting in the lost of water in the tank and the dewatering the water distribution system. The community has made arrangements for a contractor to come in and replace the C900 PVC pipe, that was displaced by the mud slide, with HDPE pipe, and reconnect the storage tank to the distribution system.

The Rural Water Association of Utah (RWAU) on behalf of the community of Henrieville has asked if the community would be eligible for emergency funding to repair the washed out transmission line. RWAU will work cooperatively with the community of Henrieville to fill out an application for financial assistance. Staff anticipates that the application will be available at the Board meeting on February 29, 2008. Further, a representative from the community as well as the operator for Henrieville is planning on attending the meeting and bringing pictures of the washout.

Because of the emergency nature of the situation, the traditional packet information will be distributed at the Board meeting.